

UNDERGROUND SERVICE ENTRANCE LOCATED ON A BUILDING

Northwestern Wisconsin Electric Company requirements:

200 AMP UL Approved Meter Socket With Lever Bypass

